

SPECIFICATION FOR APPROVAL

DESCRIPTION

Non-Halogen Cable for Photovoltaic Power System Class 5 TC Stranding Low Smoke Density.

STANDARDS

UL 4703
ROHS 2011/65/EU

CABLE CONSTRUCTION



Conductor	Stranded tinned copper
Size	4AWG
Stranding	420/0.254
Diameter	6.47mm
Inner Layer	XLPE
Minimum Average Thickness	1.39
Color	White
Outer Layer	XLPE
Minimum Average Thickness	1.14
Color	Black
Diameter	11.60 ± 0.25

ELECTRICAL PROPERTIES

Rated Voltage	1000/2000VAC
Spark Test	10000 VAC
Voltage Withstand	7500VAC/min
Conductor DC Resistance	≤ 0.882 Ω /km

Physical PROPERTIES

	Inner Layer	Outer Layer
Elongation	≥ 150%	≥ 150%
Strength	≥ 10.3Mpa	≥ 10.3Mpa
Ambient Temperature	- 40 °C up to +90 °C	
Cold bend test	UL854	
Sunlight resistance	UL2556	
Flame Test	VW-1	

Marking

(UL) E332548 PV WIRE 4AWG 90 °C WET OR DRY 1000 OR 2000V SUN RES -40 °C WUXI XINHONGYE WIRE & CABLE CO.,LTD.