

SPECIFICATION FOR APPROVAL

DESCRIPTION

Non-Halogen Cable for Photovoltaic Power System Class 5 TC Stranding Low Smoke Density.

STANDARDS

EN 50618

UL 4703

ROHS 2011/65/EU

CABLE CONSTRUCTION



Conductor	Stranded tinned copper
Size	16mm ² /6AWG
Stranding	128/0.40
Diameter	5.60mm
Inner Layer	XLPE
Minimum Average Thickness	1.39
Color	White
Outer Layer	XLPE
Minimum Average Thickness	0.90
Color	Black
Diameter	10.60 ± 0.20


ELECTRICAL PROPERTIES

Rated Voltage	EN1500DC;UL1000 OR 2000V
Spark Test	10000 VAC
Voltage Withstand	6500VAC/5min
Conductor DC Resistance	≤ 1.24 Ω /km

Physical PROPERTIES

	Inner Layer	Outer Layer
Elongation	≥ 150%	≥ 150%
Strength	≥ 10.3Mpa	≥ 10.3Mpa
Ambient Temperature	- 40℃ up to +90℃	
Bending Radius	≥ 4 × Cable OD	
Max.Conductor Temperature	120℃	
Smoke Emission Test	≥ 60%	
Flame Test	VW-1	

Marking

(UL) E332548 PV WIRE 6AWG 90 °C WET OR DRY 1000 OR 2000V SUN RES -40 °C  TÜV EN 50618
 H1Z2Z2-K 1 × 16.0mm² WUXI XINHONGYE WIRE & CABLE CO., LTD R50311889